



Bid Number/बोली क्रमांक (बिड संख्या):
GEM/2023/B/3948563
Dated/दिनांक : 19-09-2023

Bid Document/ बिड दस्तावेज़

Bid Details/बिड विवरण	
Bid End Date/Time/बिड बंद होने की तारीख/समय	09-10-2023 17:00:00
Bid Opening Date/Time/बिड खुलने की तारीख/समय	09-10-2023 17:30:00
Bid Offer Validity (From End Date)/बिड पेशकश वैधता (बंद होने की तारीख से)	120 (Days)
Ministry/State Name/मंत्रालय/राज्य का नाम	Pmo
Department Name/विभाग का नाम	Department Of Atomic Energy
Organisation Name/संगठन का नाम	Iter India Ipr
Office Name/कार्यालय का नाम	literindia Ipr Blocka Sangath Skyz Bhatmote
Total Quantity/कुल मात्रा	1
Item Category/मद केटेगरी	Cable tray Systems and Cable ladder systems (Overhead power Cable tray) (Q3)
MSE Exemption for Years of Experience and Turnover/ अनुभव के वर्षों से एमएसई छूट	No
Startup Exemption for Years of Experience and Turnover/ अनुभव के वर्षों से स्टार्टअप छूट	No
Document required from seller/विक्रेता से मांगे गए दस्तावेज़	Certificate (Requested in ATC) *In case any bidder is seeking exemption from Experience / Turnover Criteria, the supporting documents to prove his eligibility for exemption must be uploaded for evaluation by the buyer
Bid to RA enabled/बिड से रिवर्स नीलामी सक्रिय किया	No
Type of Bid/बिड का प्रकार	Two Packet Bid
Time allowed for Technical Clarifications during technical evaluation/तकनीकी मूल्यांकन के दौरान तकनीकी स्पष्टीकरण हेतु अनुमत समय	5 Days
Inspection Required (By Empanelled Inspection Authority / Agencies pre-registered with GeM)	No
Evaluation Method/मूल्यांकन पद्धति	Total value wise evaluation

EMD Detail/ईएमडी विवरण

Required/आवश्यकता	No
-------------------	----

ePBG Detail/ईपीबीजी विवरण

Required/आवश्यकता	No
-------------------	----

Splitting/विभाजन

Bid splitting not applied/बोली विभाजन लागू नहीं किया गया.

MII Purchase Preference/एमआईआई खरीद वरीयता

MII Purchase Preference/एमआईआई खरीद वरीयता	No
--	----

MSE Purchase Preference/एमएसई खरीद वरीयता

MSE Purchase Preference/एमएसई खरीद वरीयता	Yes
---	-----

1. Purchase preference to Micro and Small Enterprises (MSEs): Purchase preference will be given to MSEs as defined in Public Procurement Policy for Micro and Small Enterprises (MSEs) Order, 2012 dated 23.03.2012 issued by Ministry of Micro, Small and Medium Enterprises and its subsequent Orders/Notifications issued by concerned Ministry. If the bidder wants to avail the Purchase preference, the bidder must be the manufacturer of the offered product in case of bid for supply of goods. Traders are excluded from the purview of Public Procurement Policy for Micro and Small Enterprises. In respect of bid for Services, the bidder must be the Service provider of the offered Service. Relevant documentary evidence in this regard shall be uploaded along with the bid in respect of the offered product or service. If L-1 is not an MSE and MSE Seller (s) has/have quoted price within L-1+ 15% (Selected by Buyer) of margin of purchase preference /price band defined in relevant policy, such Seller shall be given opportunity to match L-1 price and contract will be awarded for 100%(selected by Buyer) percentage of total QUANTITY. The buyers are advised to refer the OM No.F.1/4/2021-PPD dated 18.05.2023 [OM No.1 4 2021 PPD dated 18.05.2023](#) for compliance of Concurrent application of Public Procurement Policy for Micro and Small Enterprises Order, 2012 and Public Procurement (Preference to Make in India) Order, 2017.

2. Estimated Bid Value indicated above is being declared solely for the purpose of guidance on EMD amount and for determining the Eligibility Criteria related to Turn Over, Past Performance and Project / Past Experience etc. This has no relevance or bearing on the price to be quoted by the bidders and is also not going to have any impact on bid participation. Also this is not going to be used as a criteria in determining reasonableness of quoted prices which would be determined by the buyer based on its own assessment of reasonableness and based on competitive prices received in Bid / RA process.

Cable Tray Systems And Cable Ladder Systems (Overhead Power Cable Tray) (1 pieces)**Technical Specifications/तकनीकी विशिष्टियाँ**

[* As per GeM Category Specification/जेम केटेगरी विशिष्टि के अनुसार](#)

Specification	Specification Name/विशिष्टि का नाम	Bid Requirement/बिड के लिए आवश्यक (Allowed Values)/अनुमत मूल्य
GENERIC	Type	Cable Tray System
	Installation and commissioning	Yes
CLASSIFICATION	Material of Cable tray system/Cable ladder system	Steel - Pre Galvanised
	Steel Grade (as per Table 1 of IEC:61537 latest)	ASTM: A240/A240 M - S31603 or Equivalent BIS standard
	Classification of resistance against corrosion, finish as per Table 1 of IEC:61537 latest	Class 3 for pre galvanised
	According to resistance to flame propagation	Non-Flame propagating system component
	According to electricity continuity characteristics	Without electricity continuity characteristics
	According to electrical conductivity	Electrically non-conductive system component
	Perforation base area (for cable tray) classification as per table 4 of CI 6.7 of IEC 61537 latest	Class B
	Free base area of cable ladder length as per table 5 of CI 6.8 of IEC 61537 latest	Class Y
	System component offering impact resistance up to	10 J
	Minimum temperature classification (in deg. C)	+5, -5, -15, -20, -40, -50
	Maximum temperature classification (in deg. C)	60
DIMENSION	Length (in mm)	2500 mm
	Wall thickness (in mm)	2
	Cable tray system height (in mm)	100
	Cable ladder system height (in mm)	100
CERTIFICATION	Agree to provide advance sample (s) for buyer's approval before commencement of supply (applicable in case of orders placed against bid and not applicable in case of Direct Purchase)	No

Additional Specification Parameters - Cable Tray Systems And Cable Ladder Systems (Overhead Power Cable Tray) (1 pieces)

Specification Parameter Name	Bid Requirement (Allowed Values)
Cable tray Width	600 mm
Total Cable tray Installation Length	10meters in 3 tiers, meaning total cable tray material requirement correspond to ~30m. Installation includes extension of existing cable tray with cover, of similar type as referred in picture given in Annexure-A
Cable Tray Supports	Supply and installation of cable tray supports, needed for supporting above 600mm cable tray (~15numbers similar to existing supports in picture given in Annexure-A)
Cable Laying	- Single run cable laying for 22kV, 185mm ² . 3 core, Aluminum conductor, XLPE insulated HV cable in existing 600mm cable tray and ladder. - 22kV cable is to be considered as free issue item and will be provided by ITER-India. However, supplier shall unwind and cut the cable from the cable drum - The total cable laying length shall be ~35meters. Termination kit shall be from 3M/Raychem or similar.
Cable termination	Termination for cable at both ends using HV termination kit for indoor application, suitable for above cable, including final insulation testing on prepared cable with termination

* Bidders offering must also comply with the additional specification parameters mentioned above.

Consignees/Reporting Officer/परेषिती/रिपोर्टिंग अधिकारी and/ तथा Quantity/मात्रा

S.No./क्र. सं.	Consignee Reporting/Officer/ परेषिती/रिपोर्टिंग अधिकारी	Address/पता	Quantity/मात्रा	Delivery Days/डिलीवरी के दिन
1	Mayurkumar Navinchandra Patel	380005,ITER-INDIA, IPR, BLOCK-A, SANGATH SKYZ, BHAT-MOTERA ROAD, KOTESHWAR, AHMEDABAD-380005, GUJARAT, INDIA	1	30

Buyer Added Bid Specific Terms and Conditions/क्रेता द्वारा जोड़ी गई बिड की विशेष शर्तें

1. Scope of Supply

Scope of supply (Bid price to include all cost components) : Supply Installation Testing and Commissioning of Goods

2. Generic

Actual delivery (and Installation & Commissioning (if covered in scope of supply)) is to be done at

following address

ITER-India Lab Building,
Institute for Plasma Research Institute,
Near Indira Bridge,
Bhat, Gandhinagar -382428
Gujarat, India

3. Buyer Added Bid Specific ATC

Buyer Added text based ATC clauses

1. Bidder are requested to submit duly filled, signed & stamped Scope of Supply and Technical Compliance sheet as per Annexure-A attached in Buyer Added Bid Specific ATC document.
2. Bidder are requested to note that Technical Evaluation of the bid is based only on technical compliance sheet attached in buyer added bid specific ATC documents.
3. Annexure-I attached in Buyer Added bid specific ATC Document: Self-declaration by Bidder for compliance as per Rule 144(xi) of GFR 2017.

4. Bidder need to submit "Password Protected PDF" Price Bid breakup as per format given in Annexure-II. (attached in buyer added bid specific ATC document). Password will be asked by Purchaser at the time of order placement from successful bidder only. Price Breakup shall form an integral part of the order.

5. Bidder can visit the **SITE** (ITER-India Lab Building, Institute for Plasma Research Campus, Nr. Indira Bridge, Bhat, Gandhinagar - 382428, Gujarat, India) if required. Bidder can contact Mr. Darshan Parmar (Mo. No. +91 9898564401) before visiting the site. Annexure-III during Site Visit & to be attached along with bid.

5. Bidder shall submit offer product brochure along with bid submission.

6. Bidder are requested to note that following amendment in bid required value as mentioned in technical specification above.

Specification Name	Bid Requirement (Allowed Values)	Revised Bid Requirement (Allowed Values)
According to electricity continuity characteristics	Without electricity continuity characteristics	NA
According to electrical conductivity	Electrically non-conductive system component	NA
Free base area of cable ladder length as per table 5 of CI 6.8 of IEC 61537 latest	Class Y	NA
Minimum temperature classification (in deg. C)	+5, -5, -15, -20, -40, -50	NA
Cable ladder system height (in mm)	100	NA

4. Buyer Added Bid Specific ATC

Buyer uploaded ATC document [Click here to view the file.](#)

Disclaimer/अस्वीकरण

The additional terms and conditions have been incorporated by the Buyer after approval of the Competent Authority in Buyer Organization, whereby Buyer organization is solely responsible for the impact of these clauses on the bidding process, its outcome, and consequences thereof including any eccentricity / restriction arising in the bidding process due to these ATCs and due to modification of technical specifications and / or terms and

conditions governing the bid. Any clause(s) incorporated by the Buyer regarding following shall be treated as null and void and would not be considered as part of bid:-

1. Definition of Class I and Class II suppliers in the bid not in line with the extant Order / Office Memorandum issued by DPIIT in this regard.
2. Seeking EMD submission from bidder(s), including via Additional Terms & Conditions, in contravention to exemption provided to such sellers under GeM GTC.
3. Publishing Custom / BOQ bids for items for which regular GeM categories are available without any Category item bunched with it.
4. Creating BoQ bid for single item.
5. Mentioning specific Brand or Make or Model or Manufacturer or Dealer name.
6. Mandating submission of documents in physical form as a pre-requisite to qualify bidders.
7. Floating / creation of work contracts as Custom Bids in Services.
8. Seeking sample with bid or approval of samples during bid evaluation process.
9. Mandating foreign / international certifications even in case of existence of Indian Standards without specifying equivalent Indian Certification / standards.
10. Seeking experience from specific organization / department / institute only or from foreign / export experience.
11. Creating bid for items from irrelevant categories.
12. Incorporating any clause against the MSME policy and Preference to Make in India Policy.
13. Reference of conditions published on any external site or reference to external documents/clauses.
14. Asking for any Tender fee / Bid Participation fee / Auction fee in case of Bids / Forward Auction, as the case may be.

Further, if any seller has any objection/grievance against these additional clauses or otherwise on any aspect of this bid, they can raise their representation against the same by using the Representation window provided in the bid details field in Seller dashboard after logging in as a seller within 4 days of bid publication on GeM. Buyer is duty bound to reply to all such representations and would not be allowed to open bids if he fails to reply to such representations.

[This Bid is also governed by the General Terms and Conditions/ यह बिड सामान्य शर्तों के अंतर्गत भी शासित है](#)

In terms of GeM GTC clause 26 regarding Restrictions on procurement from a bidder of a country which shares a land border with India, any bidder from a country which shares a land border with India will be eligible to bid in this tender only if the bidder is registered with the Competent Authority. While participating in bid, Bidder has to undertake compliance of this and any false declaration and non-compliance of this would be a ground for immediate termination of the contract and further legal action in accordance with the laws./जेम की सामान्य शर्तों के खंड 26 के संदर्भ में भारत के साथ भूमि सीमा साझा करने वाले देश के बिडर से खरीद पर प्रतिबंध के संबंध में भारत के साथ भूमि सीमा साझा करने वाले देश का कोई भी बिडर इस निविदा में बिड देने के लिए तभी पात्र होगा जब वह बिड देने वाला सक्षम प्राधिकारी के पास पंजीकृत हो। बिड में भाग लेते समय बिडर को इसका अनुपालन करना होगा और कोई भी गलत घोषणा किए जाने व इसका अनुपालन न करने पर अनुबंध को तत्काल समाप्त करने और कानून के अनुसार आगे की कानूनी कार्रवाई का आधार होगा।

---Thank You/धन्यवाद---